

FIRE STATION 4

PATH FORWARD

A solid orange horizontal bar spanning the width of the slide at the bottom.



Items to be Addressed

- Thoroughly clean and abate all areas containing mold traces identified in the Engineer's Report (Cleaning of floor mats to be outside to prevent cross contamination)
- Remove all debris.
- Remove all carpet and refinish floor with apoxsee or polyurethane type material.
- Remove all floor tiles and adhesive (Probable Asbestos Containing Material)
- Relocate water heater to exterior wall, install new drain pan for hot water heater.
- Move HVAC units to exterior wall.
- Paint wall services with mold resistant paint.
- Install new or reface Kitchen cabinets.
- Install chimney cap and touch up cracked roofing caulk on cables entering the building.
- Install drainage along the west wall of the building (French Drain)
- Purchase new furniture and/or dispose of old furniture or purchase new cushions (Vinyl type covering)
- Have an outside vendor to sanitize building interior

Drainage and Grade



Carpet and Flooring



Kitchen



HVAC and Water Heater



Furniture



Thank You

Questions?